

Product Certification Schedule

Schedule No: 017/004/252

Licensee: PRYSMIAN CABLES & SYSTEMS LTD, CHICKENHALL LANE, EASTLEIGH, HAMPSHIRE, SO50 6YU

Factory: PRYSMIAN CABLES & SYSTEMS LTD, CHICKENHALL LANE, EASTLEIGH, HAMPSHIRE, SO50 6YU

Specification: BS 5839-1:2002 & A2:2008 - Fire detection and fire alarm systems for buildings - Part 1: Code of practice for system design, installation, commission and maintenance. Utilizing BS7629-1:2008. Core colour requirements specified in clause 7.1 are modified to permit the use of alternative colours to meet regulatory or statutory requirements as per Note 2, Annex A1.

Type of Cable: Standard fire resistant cable requirements of BS 5839-1:2002 & A2:2008 26.2(d) utilising BS 7629-1:2008, tested to BS EN 50200:2006 (PH30 classification) and to Annex E of BS EN 50200:2006. Additionally tested to BS EN 50200:2006 and achieved PH120 classification

HAR Document: Not applicable

HAR Specification: Not applicable

Range of Approval: 1.0 to 4.0sqmm nominal cross-sectional area of conductors inclusive. 2-core to 4-core inclusive. Sheath - LTS3. Insulation - EI5. Core colour sequence - 2-core plus uninsulated CPC: red, black. 3-core plus uninsulated CPC: red, yellow, blue. 4-core plus uninsulated CPC: red, yellow, blue and black.

Origin Thread: Not applicable

Origin Mark: PRYSMIAN (B) or (B) PRYSMIAN (FP200 GOLD)

PERMISSIBLE MARKS



BASEC

YELLOW
ACETATE
THREAD

Please refer to the BASEC Product Certification Requirements

Expiry Date: 11/08/2014

Signed for and on behalf of the British Approvals Service for Cables

Date 07/07/2011

This Certificate and Schedule(s) remains the property of BASEC, and shall be returned when required.



004