

Product Certification Schedule

Schedule No: 017/006/065

Licensee: PRYSMIAN CABLES & SYSTEMS LTD, CHICKENHALL LANE, EASTLEIGH, HAMPSHIRE, SO50 6YU

Factory: PRYSMIAN CABLES & SYSTEMS LTD, WREXHAM INDUSTRIAL ESTATE, WREXHAM, LL13 9PH

Specification: BS 7846:2009 - Electric cables - Thermosetting insulated, armoured, fire resistant cables of rated voltage 600/1000 V, having low emission of smoke and corrosive gases when affected by fire - Specification

Type of Cable: Tables 4, 5 and 6 - Two-core, three-core and four-core 600/1000V cables with stranded copper conductors

HAR Document: Not applicable

HAR Specification: Not applicable

Range of Approval: 95sqmm to 400sqmm nominal cross-sectional area of conductors inclusive. Two-core to three-core inclusive. 70sqmm to 400sqmm nominal cross-sectional area of conductors inclusive. Four-core. Resistance to fire - Category F120. Sheath - LTS1. Insulation - GP8.

Origin Thread: Not applicable

Origin Mark: PRYSMIAN (W) FP600S or BRITCABLE (W) FP600S or (W) PRYSMIAN FP600S or (W) BRITCABLE FP600S

PERMISSIBLE MARKS



BASEC

YELLOW
ACETATE
THREAD

Please refer to the BASEC Product Certification Requirements

Expiry Date: 11/08/2014

Signed for and on behalf of the British Approvals Service for Cables

Date 07/07/2011

This Certificate and Schedule(s) remains the property of BASEC, and shall be returned when required.



004

Product Certification Schedule

Schedule No: 017/004/254

Licensee: PRYSMIAN CABLES & SYSTEMS LTD, CHICKENHALL LANE, EASTLEIGH, HAMPSHIRE, SO50 6YU

Factory: PRYSMIAN CABLES & SYSTEMS LTD, CHICKENHALL LANE, EASTLEIGH, HAMPSHIRE, SO50 6YU

Specification: BS 7846:2009 - Electric cables - Thermosetting insulated, armoured, fire resistant cables of rated voltage 600/1000 V, having low emission of smoke and corrosive gases when affected by fire - Specification.

Type of Cable: Tables 4, 5, 6 & 7 - Two-core, three-core, four-core and five-core 600/1000V cables with stranded copper conductors

HAR Document: Not applicable

HAR Specification: Not applicable

Range of Approval: 4sqmm to 70sqmm nominal cross-sectional area of conductors inclusive. Two-core and three-core inclusive. 4sqmm to 50sqmm nominal cross-sectional area of conductors inclusive. Four-core. 4sqmm to 35sqmm nominal cross-sectional area of conductors inclusive. Five-core. Resistance to fire - Category F120. Sheath - LTS1. Insulation - GP8. This approval is based on the use of 1.25mm armour wire for the following cables: Table 4, two-core, 4, 6 & 10sqmm, Table 5, three-core, 4 & 6 sqmm and Table 6, four-core, 4sqm, Table 7, five-core, 4sqmm.

Origin Thread: Not applicable

Origin Mark: PRYSMIAN (B) FP600S or BRITCABLE (B) FP600S or (B) PRYSMIAN FP600S or (B) BRITCABLE FP600S

PERMISSIBLE MARKS



BASEC

YELLOW
ACETATE
THREAD

Please refer to the BASEC Product Certification Requirements

Expiry Date: 11/08/2014

Signed for and on behalf of the British Approvals Service for Cables

Date 07/07/2011



This Certificate and Schedule(s) remains the property of BASEC, and shall be returned when required.

004