

Certificate of Product Approval

Licensee:

Prysmian Cables & Systems Ltd

Chickenhall Lane, Eastleigh, SO50 6YU, Hampshire, United Kingdom

Factory:

Chickenhall Lane, Eastleigh, SO50 6YU, Hampshire, United Kingdom

Standard:

BS 7846:2015

Description:

Armoured fire resistant power cables

Details:

Resistance to fire - Category F120. This approval is based on the use of 1.25mm armour wire for the following cables: Table 4, 2, 4, 6 & 10sqmm, Table 5, three-core, 4 & 6 sqmm and Table 6, four-core, 4sqmm, Table 7, five-core, 4sqmm.

Materials:

Insulation GP 8, Sheath LTS 1

Brand Name:

FP600S

Origin Mark:

PRYSMIAN (B) FP600S or (B) PRYSMIAN FP600S

Permissible Approval Marks:

BASEC



BASEC name

BASEC roundel

Signed for and on behalf of the British Approvals Service for Cables

Tony Lioveri

Date: 28/07/2020

Date of original issue: 17/03/1997

Check BASEC website to verify validity.

Page 1 of 2

BASEC, Presley House, Presley Way, Milton Keynes, MK8 0ES,

Registered in England No. 1150237, Tel: +44(0)1908267300

Email: mail@basec.org.uk, Web: www.basec.org.uk



Expiry date:
11/02/2021



Type(s) and Range(s) of Approval

Table / Clause	Code Designation	Conductor Class	Range of Cores	Min Nominal Size -sqmm	Max Nominal Size - sqmm
4	N/A	Class 2	2	4	70
5	N/A	Class 2	3	4	70
6	N/A	Class 2	4	4	50
7	N/A	Class 2	5	4	35

Signed for and on behalf of the British Approvals Service for Cables

Tony Lioveri

Date: 28/07/2020

Date of original issue: 17/03/1997

Check BASEC website to verify validity.

Page 2 of 2

BASEC, Presley House, Presley Way, Milton Keynes, MK8 0ES,

Registered in England No. 1150237, Tel: +44(0)1908267300

Email: mail@basec.org.uk, Web: www.basec.org.uk



Expiry date:
11/02/2021