

Certificate of Product Approval

Licensee:

Prysmian Cables & Systems Ltd

Chickenhall Lane, Eastleigh, SO50 6YU, Hampshire, United Kingdom

Factory:

Chickenhall Lane, Eastleigh, SO50 6YU, Hampshire, United Kingdom

Standard:

BS 7629-1:2015

Description:

Fire resistant screened cables

Details:

ENHANCED 120. Additionally tested to BS 6387:2013 Category CWZ.

Materials:

Insulation EI 5, Sheath LTS 3

Brand Name:

FPPLUS

Origin Mark:

PRYSMIAN (B) or (B) PRYSMIAN (FP PLUS)

Permissible Approval Marks:

BASEC



BASEC name

BASEC roundel

Signed for and on behalf of the British Approvals
Service for Cables

Tony Lioveri

Date: 28/07/2020

Date of original issue: 10/05/1993

Check BASEC website to verify validity.

Page 1 of 2

BASEC, Presley House, Presley Way, Milton Keynes, MK8 0ES,

Registered in England No. 1150237, Tel: +44(0)1908267300

Email: mail@basec.org.uk, Web: www.basec.org.uk



Expiry date:
11/02/2021



Type(s) and Range(s) of Approval

Table / Clause	Code Designation	Conductor Class	Range of Cores	Min Nominal Size -sqmm	Max Nominal Size - sqmm
2	N/A	Class 1	2	1.5	2.5
2	N/A	Class 2	2	1.5	2.5
2	N/A	Class 1	3	1.5	2.5
2	N/A	Class 2	3	1.5	2.5
2	N/A	Class 1	4	1.5	2.5
2	N/A	Class 2	4	1.5	2.5

Signed for and on behalf of the British Approvals Service for Cables

Tony Lioveri

Date: 28/07/2020

Date of original issue: 10/05/1993

Check BASEC website to verify validity.

Page 2 of 2

BASEC, Presley House, Presley Way, Milton Keynes, MK8 0ES,

Registered in England No. 1150237, Tel: +44(0)1908267300

Email: mail@basec.org.uk, Web: www.basec.org.uk



Expiry date:
11/02/2021