

Certificate of Product Approval

Licensee:

Prysmian Cables & Systems Ltd

Chickenhall Lane, Eastleigh, SO50 6YU, Hampshire, United Kingdom

Factory:
Oak Road

Wrexham Industrial Estate, Wrexham, LL13 9PH, Clwyd, United Kingdom

Standard:
BS 7846:2015

Description:
Armoured fire resistant power cables

Details:
Resistance to fire - Category F120.

Materials:
Insulation GP 8, Sheath LTS 1

Brand Name:
FP600S

Origin Mark:
PRYSMIAN (W) FP600S

Permissible Approval Marks:

BASEC



BASEC name

BASEC roundel

Signed for and on behalf of the British Approvals
Service for Cables

Tony Lioveri

Date: 28/07/2020

Date of original issue: 27/09/2001

Check BASEC website to verify validity.

Page 1 of 2

BASEC, Presley House, Presley Way, Milton Keynes, MK8 0ES,

Registered in England No. 1150237, Tel: +44(0)1908267300

Email: mail@basec.org.uk, Web: www.basec.org.uk



Expiry date:
11/02/2021



Type(s) and Range(s) of Approval

Table / Clause	Code Designation	Conductor Class	Range of Cores	Min Nominal Size -sqmm	Max Nominal Size - sqmm
4	N/A	Class 2	2	95	400
5	N/A	Class 2	3	95	400
6	N/A	Class 2	4	70	400

Signed for and on behalf of the British Approvals Service for Cables

Tony Lioveri

Date: 28/07/2020

Date of original issue: 27/09/2001

Check BASEC website to verify validity.

Page 2 of 2

BASEC, Presley House, Presley Way, Milton Keynes, MK8 0ES,

Registered in England No. 1150237, Tel: +44(0)1908267300

Email: mail@basec.org.uk, Web: www.basec.org.uk



Expiry date:
11/02/2021