

FP Guide to BS 8519:2010



A guide

to the selection of cable types in accordance with the recommendations of

BS 8519:2010

“Selection and installation of fire-resistant power and control cable systems for life safety and fire-fighting applications - Code of practice”

by T.L. Journeaux

Contents

Introduction	Page 3
BS 7346-6 and the 2006 edition of Approved Document B	Page 3
Fire survival times	Page 3
Cable selection and test methods	Page 4
Cable sizing and the effects of fire temperature	Page 5
Guidance on installation practice	Page 5
Protection of High Voltage supply cables	Page 5
Key Applications	Page 6
Key issues for specifiers	Page 6
Fire resistant cables - application standards	Page 7
Guidance notes	page 8

Introduction

BS 8519 is a new Code of practice giving guidance and recommendations for the "Selection and installation of fire-resistant power and control cable systems for life safety and fire-fighting applications":-

- > It specifically covers high rise and complex buildings and recognises that the fire engineered solutions developed for such buildings require a high level of performance from components of the building services including electrical supplies.
- > It is intended for designers, contractors, regulators and enforcers, fire authorities and inspectors.
- > It identifies electrical loads defined as life safety or fire-fighting and recommends minimum categories for particular applications.
- > It identifies three categories of circuits (Categories 1, 2 and 3) with fire survival times of 30 min, 60 min and 120 min.
- > It identifies appropriate cable tests for the categories.
- > It aims to ensure that the level of circuit integrity of the cables is not compromised by other electrical system components.
- > It does NOT give recommendations for the wiring of fire detection and fire alarm systems which are covered by BS 5839-1, BS 5839-6, BS 5839-8 and BS 5839-9 or emergency lighting systems covered by BS 5266-1.

BS 8519 was published in February 2010 and became effective immediately.

Relationship between BS 7346-6 and the 2006 edition of Approved Document B of The Building Regulations

BS 8519:2010 is a complete revision of BS 7346-6:2005 "Components for smoke and heat control systems - Part 6: Specification for cable systems" which has been withdrawn. The new CoP has an expanded scope to all life safety and fire-fighting systems except fire detection, fire alarm and emergency lighting. It includes much new and revised technical guidance relevant to the selection and installation of fire-resistant cables. The cable test method previously given in Annex B of BS 7346-6 has previously been published separately as BS 8491.

For large and complex buildings, Approved Document B (5.38) refers to BS 7346-6 for guidance on the selection of cables that need to operate for an extended period during a fire. This guidance is now found in BS 8519.

Fire Survival Times

Three fire survival times are recognised in BS 8519, according to the specific life safety or fire-fighting application.

For life safety systems it is recommended that the system should be capable of remaining operational for 60 minutes in large and/or complex buildings and 30 minutes in others.

For fire fighting systems it is recommended that the system should be capable of servicing active systems for 60 minutes or 120 minutes depending on the specific application.

The fire survival times are allocated categories for ease of reference:

- > Category 1 - 30 minute fire survival time
- > Category 1 - 60 minute fire survival time
- > Category 1 - 120 minute fire survival time

Cable Selection and Test Methods

Cable requirements for the three categories are split between *power* cables (larger cables generally for 3 phase circuits) and *control* cables (smaller cables with conductor sizes up to and including 4mm² and excluding 3 phase power circuits). Power cables would include supplies to plant (motors, fans etc.) whereas control cables would include interconnections (often ELV) to associated alarm and detection systems providing signals.

Power cables of 20mm overall diameter and above should meet the required fire survival time (30 min, 60 min or 120 min) when tested to BS 8491. This is the same requirement as given in BS 7346-6 and is also the same as the F30, F60 and F120 categories of BS 7846.


Prysmian FP600S high performance power cables meet the requirements for Category 1 (30 min), Category 2 (60 min) and Category 3 (120 min). Power cables that have overall diameter less than 20mm cannot currently be tested to BS 8491, but their use is allowed provided that they can be demonstrated to give the same level of resistance to fire, direct impact and water jet as required by BS 8519.

Control Cables of conductor size up to and including 4mm² should meet the required fire survival time (30 min, 60 min or 120 min) when tested to BS EN 50200 together with an additional test for resistance to fire, impact and water spray.

For Category 1, this additional test is to BS EN 50200 Annex E for 30 minutes and thus the requirement is the same as for "standard" cables to the fire alarm standard BS 5839-1.

For Category 2, this additional test is to BS 8434-2 and thus the requirement is the same as for "enhanced" cables to the fire alarm standard BS 5839-1.

For Category 3, this additional test is variant of BS 8434-2 with amended burning and water application times and the details are given in BS 8519 Annex B.



Cable sizing for the effects of fire temperature

The conductor temperature of a cable in a fire will rise above the maximum conductor temperature upon which tabulated current rating and voltage drop data is based. This will have implications for voltage drop and the effects of fault currents, which may be significant in certain applications.

Annexes of BS 8519 give guidance on the review of these factors together with a recommendation that the advice of the cable manufacturer should be sought.

The content of these informative annexes is based upon Prysmian guidance notes which are included in this booklet.

Sizing of circuit protective conductors (CPCs) is also addressed in BS 8519. Where supplementing of the cable armour with a separate external CPC is necessary to achieve the correct earth fault impedance, it is recommended that the external CPC should be not less than 25% of the cross-sectional area of the phase conductor.

Guidance on installation practice

In order to ensure that the circuit integrity of the installed cables is not compromised by other components of the system such as fixings, containment system, glands and joints, BS 8519 gives some detailed recommendations on cable installation practice. Joints, of course, should be avoided unless absolutely essential.

It is recommended that cable fixings and fixing centres should be in accordance with the cable manufacturer's recommendations. Such recommendations for **Prysmian FP cables** are given in the appropriate cable data sheet.

It is recommended that robust armoured cables (such as those meeting BS 8491 and BS 7846) are installed either fixed direct to the building structure or on a cable management system. In cases where additional mechanical protection is required, installation on a cable management system or in a containment system is recommended. Any such cable management systems are required to maintain their function in the presence of the same flame, mechanical impact and water jet conditions and for the same time period as required for the cables, although no specific tests are given as they are still in the process of development. Manufacturers of fire rated cable management systems should be consulted regarding the design and specification of compliant systems. (See table 12 of guidance note no.1 wiring regs BS 7671).

Protection of High Voltage Supply Cables

For security of supply, BS 8519 recommends that mains supply cables serving life safety and fire fighting systems should directly enter the fire rated switch rooms and not pass through the building. However, it is recognised that in certain instances such cables may have to be routed through the building, in which case they should be fire protected by a protective system for the appropriate survival time.

As suitable HV cables with intrinsic resistance to fire are not available, normal cables (e.g. BS 7835) should be used with appropriate protection. Protection may be achieved by installation of the cable within a concrete trench with concrete cover, routing within a dedicated shaft or void of the appropriate fire rating, or enclosure throughout their length by passive fire protection material giving 120 minute fire resistance together with the capability of withstanding the effects of a water jet after such exposure. Certain high performance systems based on composite panels of fibre reinforced cement bonded to steel sheets are claimed to be suitable.

BS 8519 recommends that the performance of the enclosure should be assessed in accordance with BS EN 1366-5:2003 for integrity and thermal insulation under conditions of fire outside the duct. In order to ensure no adverse effect on the cable, the measured temperature inside the duct should not exceed the initial temperature by more than 180 °C. Manufacturers of fire rated systems suitable for cable protection should be consulted regarding the design of compliant systems.

Restriction of the temperature rise within the fire protective system to 180°C will ensure that XLPE insulated cables to BS 7835 will operate for the required 120 minutes.


Key Applications

Key applications where the guidance and recommendations of BS 8519 would be appropriate to ensure best practice and provide a secure means of compliance with Approved Document B would include:

- > Supply and control of Smoke barriers, Smoke control dampers, Smoke curtains and Smoke fans
- > Supply and control of Fire barriers
- > Supply and control of Smoke and Heat Exhaust Ventilation Systems
- > Supply and control to pressurization systems
- > Fire-fighting and evacuation lift supplies
- > Sprinkler pumps, water mist, gaseous, powder, water spray and automatic foam extinguishing systems
- > Wet riser pumps

Key issues for specifiers

- > BS 8519 is an important new Code of Practice giving guidance and recommendations for the selection and installation of fire resistant power and control cables for a range of life safety and fire fighting applications.
- > BS 8519 does not cover the wiring of fire detection and fire alarm systems which are still covered by the pre-existing BS 5839-1, BS 5839-6, BS 5839-8 and BS 5839-9 or emergency lighting systems which are covered by the pre-existing BS 5266-1.
- > BS 8519 replaces BS 7346-6, which is withdrawn and provides a secure route to compliance with Approved Document B of The Building Regulations for large and complex buildings.
- > BS 8519 introduces the concept of time based fire survival times (30 min, 60 min and 120 min) defined as Categories 1, 2 and 3 for both power and control cables.
- > BS 8519 references existing test methods and performance levels (BS 8491, BS EN 50200, BS 8434-2) except in the case of Category 3 control cables where a variant of BS 8434-2 is defined.
- > BS 8519 does not require the development of any new cable types to meet its new requirements as existing **Prysmian FP cables** are already available to meet each of the performance categories for both power and control applications.



Guidance Notes: As printed in BS 8519:2010

A Current ratings and voltage drop for cables in a fire:

When a cable is involved in a fire, the conductor temperature will rise above the maximum conductor temperature upon which the tabulated current rating and voltage drop data given in Prysmian Cables & Systems Ltd. data sheets is based.

In carrying a set current, a cable with its conductor temperature at 950 °C will experience a greater temperature rise due to current loading than a cable with its conductor temperature at 90 °C. However, the additional temperature rise due to this factor will be less than 50 °C and is not significant in relation to the temperature rise caused by fire.

The voltage drop at typical fire temperatures will be higher than at 90 °C and this may be significant for certain types of load. Assuming a worst case of the total length of the cable run in the fire, it may be necessary to increase the conductor size as illustrated in the following examples.

Voltage drop calculations for cables in a fire:

The process of calculating voltage drop of a cable is normally straight forward. Tabulated values are multiplied by the length of run and current to be carried, to give the expected voltage drop.

It should be noted that the tabulated values assume that the cable conductor temperature is at its maximum permitted normal operating temperature.

If the cable is involved in a fire, the conductor temperature and hence the resistance would be higher, therefore the voltage drop would be higher.

The problem in determining the voltage drop for a run of cable in a fire is to know the conductor temperature at each point along its length. Therefore assumptions have to be made in calculating what the voltage drop would be.

To illustrate the effect of assuming different lengths of cable being involved in a fire, two sets of examples are given, one based on 5 A and the other based on 200 A load.

Example 1.0:

Assume a 2 core 2.5mm² FP400 cable carrying 5 A over 50 m.

In normal operation the voltage drop would be:

$$19 \times 0.001 \times 5 \times 50 = \underline{4.75 \text{ V}}$$

Where 19 is the mV/A/m for FP400 2.5mm² at 90 °C

Example 1.1:

Assume a 2 core 2.5mm² FP400 cable carrying 5 A over 50 m. Assume 2 m are at 750 °C and the rest of the cable is at 90 °C. Volt drop would be:

$$(19 \times 0.001 \times 5 \times 48) + (19 \times 0.001 \times 3.0342 \times 5 \times 2) = \underline{5.14 \text{ V}}$$

Example 1.2:

Assume a 2 core 2.5mm² FP400 cable carrying 5 A over 50 m. Assume all 50 m are at 750 °C. Volt drop would be:

$$19 \times 0.001 \times 3.0342 \times 5 \times 50 = \underline{14.41 \text{ V}}$$

Example 2.0:

Assume a 2 core 120mm² FP600S cable carrying 200 A over 50 m. In normal operation the volt drop would be:

$$0.42 \times 0.001 \times 200 \times 50 = \underline{4.2 \text{ V}}$$

Where 0.42 is the mV/A/m for FP600S 120mm² at 90 °C.

Example 2.1:

Assume a 2 core 120mm² FP600S cable carrying 200 A over 50 m. Assume 2m are at 750 °C and the rest of the cable is at 90°C. Volt drop would be:

$$(0.42 \times 0.001 \times 200 \times 48) + (0.42 \times 0.001 \times 3.0342 \times 200 \times 2) = \underline{4.45 \text{ V}}$$

Example 2.2:

Assume a 2 core 120mm² FP600S cable carrying 200 A over 50 m. Assume all 50 m are at 750 °C. Volt drop would be:

$$0.042 \times 0.001 \times 3.042 \times 200 \times 5 = \underline{12.74 \text{ V}}$$

As can be seen from these examples, although the voltage drop has increased from normal operation, with part of a cable or all the cable in a fire, the percentage drop from a 240 V single phase supply does not increase significantly.

This to say :

Example 1, would give 1.98%, 2.14% and 6% respectively.

Example 2, would give 1.75%, 1.9% and 5.3% respectively.

From these percentage volt drop values, it would seem unlikely that a fire would have a significant effect on most equipment being supplied by the cable, even in the example of the worst case given above.

However if it is required to limit the volt drop to 4% for the example when the whole length of cable is in the fire, e.g. motors running fire fighting water pumps; then the cable sizes in examples 1.2 and 2.2 would have to be

Tel: 0845 767 8345
Fax: 023 8029 5465

UK Technical helpline
Tel: 0845 767 8345
Fax: 023 8029 5002

Prysmian Cables & Systems Limited
Chickenhall Lane
Eastleigh
Hampshire
SO50 6YU
United Kingdom
www.prysmian.co.uk
www.fpcables.co.uk

Overseas sales enquiries

Tel: +44 (0) 23 5029 5481
Fax: +44 (0) 23 8029 5465

Overseas technical

Tel: +44 (0) 23 8029 5481
Fax: +44 (0) 23 8029 5002

Information hotline

Tel: +44 (0) 23 8029 5029
Fax: +44 (0) 23 8029 5437



Should you have any concerns about unsafe, non-approved or counterfeit cable, please contact the ACI

Tel: 020 8946 6978
Email: report@aci.org.uk