

Certificate of Product Approval

Certificate Number: 077h

Issue: 04

PRYSMIAN CABLE & SYSTEMS LIMITED

Chickenhall Lane
Bishopstoke
Eastleigh
Hants
SO50 6YU
United Kingdom



is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix having complied with the requirements of the standard(s) detailed below:

Product(s)

Cable Types as listed below:
FP Plus Flex
See Certificate Appendix for details

Standard(s) (see Appendix for details)

BS 7629-1:2015 (ENHANCED120)
BS 6387:2013 (C,W,Z)
EN 50200:2015 (PH120)
BS 8434-2:2003+A2:2009 (120 mins)
BS 5839-1:2013 (Clause 26.2e Enhanced)

Select relevant text, type new text or hit spacebar.

Damien Ward

Signed for LPCB

Damien Ward
Certification Scheme Manager

10 August 2016
Date of Issue

08 April 2005
Date of First issue



This certificate and appendix remain the property of BRE Global Ltd and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

LPCB is part of BRE Global Ltd, Garston, Watford, WD25 9XX
T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: enquiries@breglobal.com



Appendix to Certificate No: 077h PRYSMIAN CABLE & SYSTEMS LIMITED

Issue: 04

Product name						LPCB Ref. No.
FP Plus Flex						077h/01
Nominal csa of conductor (mm ²)	Core Construction (excluding drain wire and earth)	BS 7696-1	BS 6387	EN 50200	BS 8434-2	BS 5839-1 Clause 26.2
1.0	2 ⁽¹⁾	ENHANCED 120 ⁽³⁾	C,W,Z	PH120	120min ⁽⁴⁾	Enhanced ⁽⁵⁾
1.5	2, 3 & 4 ⁽¹⁾	ENHANCED 120 ⁽³⁾	C,W,Z	PH120	120min ⁽⁴⁾	Enhanced ⁽⁵⁾
2.5	2, 3 & 4 ⁽²⁾	ENHANCED 120 ⁽³⁾	C,W,Z	PH120	120min ⁽⁴⁾	Enhanced ⁽⁵⁾
4.0	2, 3 & 4 ⁽²⁾	ENHANCED 120 ⁽³⁾	C,W,Z	PH120	120min ⁽⁴⁾	Enhanced ⁽⁵⁾

Uo/U 300/500V

Notes:

1. Solid conductor only.
2. Stranded conductor only.
3. In meeting the requirements of BS 7629-1:2015, the FP Plus Flex cables listed met the requirements for smoke density of EN 61034-2:2005+A1:2013, and achieved less than 0.5% HCl for the insulation, binder tape and outer covering when tested in accordance with EN 60754-1:2014 and in addition also met the fire resistance requirements of BS 6387:2013 Categories CWZ.
4. The duration of 120min when tested in accordance with BS 8434-2:2003+A2:2009 is achieved by 60min for the fire and mechanical shock phase and an additional 60min for the fire, mechanical shock and water phase.
5. The FP Plus Flex cables listed conform to BS 7629-1:2015, met Class PH120 when tested in accordance with EN 50200:2015 and met a duration of 120min when tested in accordance with BS 8434-2:2003+A2:2009 and hence met the requirements for an enhanced fire resistant cable as described in Clause 26.2 of BS 5839-1:2013.

Choose an item.

Damien Ward

Signed for LPCB

Damien Ward

Certification Scheme Manager

10 August 2016

Date of Issue

08 April 2005

Date of First issue



This certificate and appendix remain the property of BRE Global Ltd and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

LPCB is part of BRE Global Ltd, Garston, Watford, WD25 9XX
T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: enquiries@breglobal.com



bre

Certificate of Product Approval

Certificate Number: 077g

Issue: 08

PRYSMIAN CABLE & SYSTEMS LIMITED

Chickenhall Lane
Bishopstoke
Eastleigh
Hants
SO50 6YU
United Kingdom

is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix having complied with the requirements of the standard(s) detailed below:

Product(s)

Cable Types as listed below:
FP Plus
See Certificate Appendix for details

Standard(s) (see Appendix for details)

BS 7629-1:2015 (ENHANCED 120)
BS 6387:2013 (CWZ)
EN 50200:2015 (Class PH120)
BS 8434-2:2003+A2:2009 (120 mins)
BS 5839-1:2013 (Clause 26.2e Enhanced)

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

Signed for LPCB

Karen Coull
Certification Scheme Manager

01 September 2017
Date of Issue

13 October 2003
Date of First issue



This certificate and appendix remain the property of BRE Global Ltd and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

LPCB is part of BRE Global Ltd, Garston, Watford, WD25 9XX
T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: enquiries@breglobal.com



Appendix to Certificate No: 077g PRYSMIAN CABLE & SYSTEMS LIMITED

Issue: 08

Product name						LPCB Ref. No.
FP Plus						077g/02
Nominal csa of conductor (mm ²)	Core Construction (excluding drain wire and earth)	BS 7629-1	BS 6387	EN 50200	BS 8434-2	BS 5839-1 Clause 26.2
1.5	2 ⁽¹⁾	ENHANCED 120	C,W,Z	PH120	120min ⁽³⁾	Enhanced ⁽⁴⁾
2.5	2 ⁽¹⁾	ENHANCED 120	C,W,Z	PH120	120min ⁽³⁾	Enhanced ⁽⁴⁾

Uo/U 300/500V

Notes:

1. Solid conductor only.
2. In meeting the requirements of BS 7629-1:2015, the FP Plus cables listed met the requirements for smoke density of EN 61034-2:2005+A1:2013, and achieved less than 0.5% HCl for the insulation, binder tape and outer covering when tested in accordance with EN 60754-1:2014 and in addition also met the fire resistance requirements of BS 6387:2013 Categories CWZ.
3. The duration of 120min when tested in accordance with BS 8434-2:2003+A2:2009 is achieved by 60min for the fire and mechanical shock phase and an additional 60min for the fire, mechanical shock and water phase.
4. The FP Plus cables listed conform to BS 7629-1:2015, met Class PH120 when tested in accordance with EN 50200:2015 and met a duration of 120min when tested in accordance with BS 8434-2: 2003+A2:2009 and hence met the requirements for an enhanced fire resistant cable as described in Clause 26.2 of BS 5839-1:2013.

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.



Signed for LPCB

Karen Coull
Certification Scheme Manager

01 September 2017
Date of Issue

13 October 2003
Date of First issue



This certificate and appendix remain the property of BRE Global Ltd and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

LPCB is part of BRE Global Ltd, Garston, Watford, WD25 9XX
T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: enquiries@breglobal.com




Appendix to Certificate No: 077g PRYSMIAN CABLE & SYSTEMS LIMITED

Issue: 08

Product name						LPCB Ref. No.
FP Plus						077g/03
Nominal csa of conductor (mm ²)	Core Construction (excluding drain wire and earth)	BS 7629-1	BS 6387	EN 50200	BS 8434-2	BS 5839-1 Clause 26.2
1.5	2, 3 & 4 ⁽¹⁾	ENHANCED 120	C,W,Z	PH120	120min ⁽³⁾	Enhanced ⁽⁴⁾
2.5	2, 3 & 4 ⁽¹⁾	ENHANCED 120	C,W,Z	PH120	120min ⁽³⁾	Enhanced ⁽⁴⁾

Uo/U 300/500V

Notes:

1. Solid conductor only.
2. In meeting the requirements of BS 7629-1:2015, the FP Plus Flex cables listed met the requirements for smoke density of EN 61034-2:2005+A1:2013, and achieved less than 0.5% HCl for the insulation, binder tape and outer covering when tested in accordance with EN 60754-1:2014 and in addition also met the fire resistance requirements of BS 6387:2013 Categories CWZ.
3. The duration of 120min when tested in accordance with BS 8434-2:2003+A2:2009 is achieved by 60min for the fire and mechanical shock phase and an additional 60min for the fire, mechanical shock and water phase.
4. The FP Plus cables listed conform to BS 7629-1:2015, met Class PH120 when tested in accordance with EN 50200:2015 and met a duration of 120min when tested in accordance with BS 8434-2:2003+A2:2009 and hence met the requirements for an enhanced fire resistant cable as described in Clause 26.2 of BS 5839-1:2013.

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.



Signed for LPCB

Karen Coull
Certification Scheme Manager

01 September 2017
Date of Issue

13 October 2003
Date of First issue



This certificate and appendix remain the property of BRE Global Ltd and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

LPCB is part of BRE Global Ltd, Garston, Watford, WD25 9XX
T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: enquiries@breglobal.com


